


GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT



From
V.Papaiah, M.Sc, B.Ed.,
District Fire Officer
Ranga Reddy District.

To
The District Educational Officer,
Ranga Reddy District.

Rc.No.93/DFO/WZ/RR/2019, dated: 05.03.2019.

Sir,

Sub: Telangana State Disaster Response & Fire services Department – Renewal of No Objection Certificate for Occupancy to the Existing Educational Building located at M/s. The Global Edge School, Sy.No:166&167, Kokapet, Narsinghi(V), Gandipet(M), R.R. District - Reg.

Ref:- 1) Rc. No. 561/DFO/RR/2017, dt. 07.11.2017 of The Global Edge School, Sy.No:166&167, Kokapet, Narsinghi(V), Gandipet(M), R.R.District.
2) Inspection Report of Asst. District Fire Officer, Ranga Reddy District and Station Fire Officer, dt.19.02.2019.

\$\$\$\$\$

With reference 1st cited, the Authorized representative has reported that he has constructed Educational Building without obtaining Provisional No-Objection Certificate from this Department and requested to issue the No-Objection Certificate for Occupancy to the Existing Educational Building M/s. The Global Edge School, Sy.No:166&167, Kokapet, Narsinghi(V), Gandipet(M), R.R.District.

2) Vide reference 2nd cited, the Asst. District Fire Officer Ranga Reddy District and Station Fire Officer, has inspected the existing Educational Building on 19-02-2019 and recommended for issue of No Objection Certificate for Occupancy for the above Educational Building.

3). Particulars of Educational Building:-

i) Height of the building 9.10 Metres.

ii) Open spaces:

Direction	Required as per NBC-2005	Provided	Deficit/Remarks
North	06.00 Metres	06.50 Metres	N.A
East	06.00 Metres	07.86 Metres	N.A
South	06.00 Metres	08.75 Metres	N.A
West	06.00 Metres	06.50 Metres	N.A

iii) Floor wise particulars:

Sl.No.	Floor	Floor Area in Sq.Metres	Occupancy	Maximum Occupant Load as per NBC,2005
1	Ground floor	1639.00 Sq.Mtrs	Educational	160
2	First floor	1650.00 Sq.Mtrs	Educational	160
3	Second floor	1650.00 Sq.Mtrs	Educational	160
	Total	4939.00 Sq.Mtrs	--	480

The Management has remitted fire precaution Fee for Rs.49390=00 (Rupees Forty Nine Thousands Three Hundred and Ninety only) Vide Challan No.53849 dated: 05.02.2019 S.B.I Gruhakalpa Branch, Hyd.

iv) Means of escape:

Sl. No.	Details of Staircase	Provided		Deficit
		No's	Width in Mtrs	
1	Internal Staircase	4 No	2.00 Metres	Nil
	Total	4No's	8.00Metres	

Correspondent
The Global Edge School
Kokapet, Narsing-500 075.
R.R. Dist.

M. Swath Reddy

Principal
The Global Edge School
Kokapet, Narsing-500 075.
R.R. Dist.

Principal
The Global Edge School
Narsing - 500 075
R.R. Dist.

v) Details of Occupant load per unit Exit Width in each floor.

Sl. No.	Floor	Builtup Area in Sq.Metres	No. of Occupants	Means of Escape as per NBC,2005	Provided
1	Ground floor	1639.00 Sq.Mtrs	160		
2	First Floor	1650.00 Sq.Mtrs	160		
3	Second floor	1650.00 Sq.Mtrs	160		
	Total	4939.00 Sq.Mtrs	480		

vi) The following fire fighting system provided by the builder as per Table-23 of N.B.C. Part-I


Sl. No.	Fire Safety measures	Required as per Table 23 of NBC of India 2005	Provided	Deficiency
1	Fire Extiguishers	16 Nos	16 Nos	Nil
2	Hose Reel	3 Nos	3 Nos	Nil
3	a)Terrace Tank capacity 10,000Ltrs b)Additional 5,000 ltrs if area of basement area Exceeded 200sq.mtrs	Provided 15000Ltrs	Provided 15000Ltrs	Nil
4	a)One Booster pump of 450 LPM b)One Booster pump of 900 LPM	900LPM,1 Nos	1 Nos	Nil

vii) Therefore Office has No Objection for Occupancy to the Existing Educational M/s. The Global Edge School, Sy.No:166&167, Kokapet, Narsinghi(V), Gandipet(M), R.R.District.


i	All the fire protection arrangements shall be maintained in good repair as seen during inspection
ii	All the escape/exit routes shall not be kept locked/blocked or encroached
iii	All the occupants must know the correct method of operation of the fire fighting system installed
iv	Any loss of life or property due to non-functioning of fire safety measures and other installation shall be the responsibility of the management.
v	All students / staff members of the institution shall be trained to operate the fire safety equipments during emergency.
vi	Addition /alteration, if any in the building may be obtained with prior permission from this department
vii	Mock drills should be conducted once in 3 months for initial two years Thereafter, once in every 6 months


This Occupancy clearance is valid for a period of One year from the date of issue.

Yours faithfully


 5/3/19
 District Fire Officer
 Ranga Reddy District.

Copy to the Station Fire Officer,
 Copy to the Management of Building M/s. The Global Edge School, Sy.No:166&167, Kokapet, Narsinghi(V), Gandipet(M), R.R.District.


 Correspondent
The Global Edge School
 Kokapet, Narsing-500 075.
 R.R. Dist.


 Principal
The Global Edge School
 Narsing-500 075
 Kokapet, R.R. Dist.